

AN ORDINANCE BY THE CITY OF MORGANTOWN AMENDING SECTIONS 923.06 AND 923.13 OF ITS STREETS, UTILITIES AND PUBLIC SERVICES CODE, AS THE SAME APPLIES TO INDUSTRIAL WASTES DISCHARGED INTO THE SEWER SYSTEM AND ANCILLARY SERVICES REGARDING INDUSTRIAL WASTES.

The City of Morgantown hereby ordains that Sections 923.06 and 923.13 of its Streets, Utilities and Public Services Code is amended as follows (new matter underlined, deleted matter struck through):

923.06 POLLUTANT LIMITATIONS.

(a) The General Manager is authorized to establish local Limits pursuant to 40 CFR 403.5(c)

(b) Limitations for specific pollutants of concern that may cause pass through, inhibition or cause a degradation of sludge quality have been developed by the Board for specific pollutants of concern. The limits are derived from a mass basis and are allocated on a mass proportion basis to each individual industrial user. The Board also reserves the right to convert mass allocations to concentration based permit limitations and to impose limitations as monthly average, daily maximum, or instantaneous maximum limitations. The Board may derive daily maximum limits by applying a factor of approximately 1.5 to the monthly average limits. Specific limitations for any individual industrial user are delineated in the user's contribution permit.

The following specific total pollutant mass limitations are available to industrial users. These total pollutant mass limitations are monthly average limits. Individual mass limitations are fractional amounts of the listed totals and are proportionally based on the individual industry's contributions. Pollutants not listed may be regulated by the industry's specific wastewater contribution permit.

Cadmium	0.11 lbs./day
Total Chromium	0.90 lbs./day
Copper	2.30 lbs./day
Cyanide	1.60 lbs./day
Lead	1.10 lbs./day
Mercury	0.07 0.03 lbs./day
Nickel	3.60 lbs./day
Silver	2.30 lbs./day
Zinc	6.30 lbs./day
Arsenic	0.28 lbs./day

(c) The General Manager may develop Best Management Practices (BMPs), by ordinance or in individual wastewater discharge permits to implement Local Limits and the requirements of Section 923.04.

(Ord. 11-21. Passed 6-7-11.)

923.13 FEES.

(a) Purpose. It is the purpose of this section to provide for the recovery of costs from users of the City's wastewater disposal system for the implementation of the programs established herein.

(b) Charges and Fees. The City hereby adopts the following charges and fees associated with sampling, analysis, monitoring, inspections and surveillance procedure, which shall be payable to the Board:

(1) For reimbursement of costs of setting up and operating the City's pretreatment program: ~~\$65.00~~ \$75.00 per man-hour

(2) For monitoring, inspection and surveillance procedures: ~~\$65.00~~ \$75.00 per man-hour;

(3) For reviewing accidental/slug discharge procedures and construction: ~~\$65.00~~ \$75.00 per man-hour;

(4) For sampling and analysis, each individual permitted user shall reimburse the Board for the actual cost incurred;

(5) For wastewater contribution permit: \$500.00 (non-refundable);

(6) For filing appeals to the Board: \$300.00;

(7) For consistent removal by the City of pollution not otherwise subject to Federal pretreatment standard:

$$C_i = V_o V_i = B_o B_i + S_o S_i$$

C_i - charge to industrial users per year.

Vo - average unit cost of transport and treatment chargeable to volume, in dollars per gallon

Vi - volume of wastewater from industrial users, in gallons per year

Bo - average unit cost of treatment, chargeable to Biochemical Oxygen Demand (BOD), in dollars per pound.

Bi - weight of BOD from industrial users, in pounds per year.

So - average cost of treatment (including sludge treatment) chargeable to total solids, in dollars per pound.

Si - weight of total solids from industrial users in pounds per year.

These fees relate solely to the matters covered by this article and are separate from all other fees chargeable by the City.

(Ord. 11-21. Passed 6-7-11.)

First Reading: _____

MAYOR

Second Reading: _____

CITY CLERK

Filed: _____

Recorded: _____